


CANDELA DISTRIBUTION				CANDELA TABLE			LUMINANCE (cd/sq.m)			LUMENS PER ZONE		ZONAL LUMEN SUMMARY								
					0°	90°		0.00°	90.00°		ZONE	LUMENS		ZONE	UMENS	% LUMINAIRE				
				0°	518	516	0.00°	10788	10754	0° - 10°	49	0° - 20°	187	14%						
				10°	506	506	45.00°	9232	9787	10° - 20°	138	0° - 30°	391	29%						
				20°	470	474	55.00°	8642	9202	20° - 30°	205	0° - 40°	632	46%						
				30°	416	422	65.00°	8189	8404	30° - 40°	240	0° - 60°	1093	80%						
				40°	349	364	75.00°	6965	7026	40° - 50°	245	0° - 80°	1345	98%						
				50°	276	294	85.00°	4678	4274	50° - 60°	216	0° - 90°	1366	100%						
				60°	200	212				60° - 70°	163									
				70°	126	128				70° - 80°	89									
				80°	50	49				80° - 90°	22									
90°	3	2																		
CONE OF LIGHT				INDOOR COEFFICIENTS OF UTILIZATION																
MOUNTING HEIGHT	FC AT BEAM CENTER	BEAM DIA. 0°-180°	BEAM DIA. 90°-270°	pf	20%												0%			
				pc	80%				70%				50%				0%			
				pw	70%	50%	30%	10%	70%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0%	
6.0 m	14.4 lx	15.7 m	16.1 m	0	119	119	119	119	116	116	116	111	111	111	106	106	102	102	102	100
8.0 m	8.1 lx	20.9 m	21.4 m	1	109	104	100	96	106	102	98	95	98	95	92	94	91	89	90	88
10.0 m	5.2 lx	26.1 m	26.8 m	2	99	91	84	79	97	89	83	78	86	80	76	82	78	74	79	76
12.0 m	3.6 lx	31.4 m	32.2 m	3	91	80	72	66	88	79	71	65	76	69	64	73	67	63	70	66
14.0 m	2.6 lx	36.6 m	37.5 m	4	83	71	62	56	81	70	62	55	67	60	55	65	59	54	63	57
16.0 m	2.0 lx	41.8 m	42.9 m	5	76	64	55	48	74	62	54	48	60	53	47	58	52	47	57	51
18.0 m	1.6 lx	47.1 m	48.2 m	6	71	57	48	42	69	56	48	42	55	47	41	53	46	41	51	45
20.0 m	1.3 lx	52.3 m	53.6 m	7	65	52	43	37	64	51	43	37	50	42	37	48	42	37	47	41
				8	61	48	39	33	59	47	39	33	46	38	33	44	38	33	43	37
				9	57	44	35	30	56	43	35	30	42	35	30	41	34	30	40	34
				10	53	40	32	27	52	40	32	27	39	32	27	38	31	27	37	31