


CANDELA DISTRIBUTION				CANDELA TABLE			LUMINANCE (cd/sq.m)			LUMENS PER ZONE		ZONAL LUMEN SUMMARY							
				0°		90°	0.00°		90.00°	ZONE		LUMENS	ZONE	UMENS	% LUMINAIRE				
				0°	2121	2117	0.00°	22091	22051	0° - 10°	200	0° - 20°	765	14%					
				10°	2071	2072	45.00°	18682	19377	10° - 20°	565	0° - 30°	1602	29%					
				20°	1921	1936	55.00°	17463	18282	20° - 30°	837	0° - 40°	2582	47%					
				30°	1694	1725	65.00°	16004	16886	30° - 40°	980	0° - 60°	4436	80%					
				40°	1417	1461	75.00°	13621	14702	40° - 50°	987	0° - 80°	5438	98%					
				50°	1116	1164	85.00°	8910	9484	50° - 60°	868	0° - 90°	5522	100%					
				60°	806	847				60° - 70°	645								
				70°	492	522				70° - 80°	357								
				80°	193	213				80° - 90°	84								
90°	5	5																	
CONE OF LIGHT				INDOOR COEFFICIENTS OF UTILIZATION															
MOUNTING HEIGHT	FC AT BEAM CENTER	BEAM DIA. 0°-180°	BEAM DIA. 90°-270°	pf	20%												0%		
				pc	80%				70%				50%				0%		
				pw	70%	50%	30%	10%	70%	50%	30%	10%	50%	30%	10%	50%	10%	0%	
6.0 m	58.9 lx	15.1 m	15.8 m	0	119	119	119	119	116	116	116	116	111	111	111	106	106	102	100
8.0 m	33.1 lx	20.1 m	21.1 m	1	109	104	100	96	106	102	98	95	98	95	92	94	91	88	84
10.0 m	21.2 lx	25.1 m	26.4 m	2	99	91	85	79	97	89	83	78	86	81	76	83	78	74	71
12.0 m	14.7 lx	30.2 m	31.7 m	3	91	80	72	66	88	79	71	65	76	69	64	73	68	63	60
14.0 m	10.8 lx	35.2 m	36.9 m	4	83	71	63	56	81	70	62	56	67	60	55	65	59	54	51
16.0 m	8.3 lx	40.2 m	42.2 m	5	77	64	55	48	74	63	54	48	61	53	48	59	52	47	44
18.0 m	6.5 lx	45.3 m	47.5 m	6	71	58	49	42	69	57	48	42	55	47	42	53	46	41	39
20.0 m	5.3 lx	50.3 m	52.8 m	7	66	52	44	37	64	51	43	37	50	42	37	48	42	37	35
				8	61	48	39	34	60	47	39	33	46	38	33	45	38	33	31
				9	57	44	36	30	56	43	35	30	42	35	30	41	35	30	28
				10	54	41	33	27	52	40	32	27	39	32	27	38	32	27	25