


CANDELA DISTRIBUTION				CANDELA TABLE			LUMINANCE (cd/sq.m)			LUMENS PER ZONE		ZONAL LUMEN SUMMARY									
				0°		90°	0.00°		90.00°	ZONE	LUMENS	ZONE	UMENS	% LUMINAIRE							
				0°		1010	1008	0.00°		21045	20992	0° - 10°	95	0° - 20°	364	14%					
				10°		987	987	45.00°		18020	18502	10° - 20°	269	0° - 30°	763	29%					
				20°		918	924	55.00°		16880	17410	20° - 30°	399	0° - 40°	1231	46%					
				30°		812	824	65.00°		15473	16389	30° - 40°	468	0° - 60°	2118	80%					
				40°		682	698	75.00°		13665	13703	40° - 50°	471	0° - 80°	2605	98%					
				50°		539	555	85.00°		9365	8407	50° - 60°	415	0° - 90°	2649	100%					
				60°		390	402					60° - 70°	312								
				70°		238	250					70° - 80°	175								
				80°		98	96					80° - 90°	45								
90°		7	4																		
CONE OF LIGHT				INDOOR COEFFICIENTS OF UTILIZATION																	
MOUNTING HEIGHT	FC AT BEAM CENTER	BEAM DIA. 0°-180°	BEAM DIA. 90°-270°	pf	20%												0%				
				pc	80%				70%				50%				0%				
				pw	70%	50%	30%	10%	70%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0%		
6.0 m	28.1 lx	15.4 m	15.8 m	0	119	119	119	119	116	116	116	116	111	111	111	106	106	102	102	100	
8.0 m	15.8 lx	20.6 m	21.1 m	1	109	104	100	96	106	102	98	95	98	95	92	94	91	89	90	84	
10.0 m	10.1 lx	25.7 m	26.3 m	2	99	91	84	79	97	89	83	78	86	80	76	82	78	74	79	70	
12.0 m	7.0 lx	30.8 m	31.6 m	3	91	80	72	66	88	79	71	65	76	69	64	73	67	63	70	59	
14.0 m	5.2 lx	36.0 m	36.9 m	4	83	71	62	56	81	70	62	55	67	60	55	65	59	54	63	51	
16.0 m	3.9 lx	41.1 m	42.1 m	5	76	64	55	48	74	63	54	48	60	53	47	58	52	47	57	44	
18.0 m	3.1 lx	46.2 m	47.4 m	6	71	57	48	42	69	56	48	42	55	47	42	53	46	41	51	39	
20.0 m	2.5 lx	51.4 m	52.7 m	7	66	52	43	37	64	51	43	37	50	42	37	48	42	37	47	34	
				8	61	48	39	33	59	47	39	33	46	38	33	44	38	33	43	37	31
				9	57	44	36	30	56	43	35	30	42	35	30	41	34	30	40	34	28
				10	54	40	33	27	52	40	32	27	39	32	27	38	32	27	37	31	25