


SPACING CRITERIA: 1.19



INDOOR COEFFICIENTS OF UTILIZATION

pf pc pw	20%																		0%
	80%			70%			50%			30%			10%			0%			
	70%	50%	30%	10%	70%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0%	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	
1	109	104	100	96	106	102	98	95	98	95	92	94	91	89	90	88	86	84	
2	99	91	85	79	97	89	83	78	86	81	76	83	78	74	80	76	73	71	
3	91	80	72	66	88	79	71	65	76	69	64	73	68	63	70	66	62	60	
4	83	71	63	56	81	70	62	56	67	60	55	65	59	54	63	58	53	51	
5	77	64	55	48	74	63	54	48	61	53	48	59	52	47	57	51	47	44	
6	71	58	49	42	69	57	48	42	55	47	42	53	46	41	52	46	41	39	
7	66	52	44	37	64	51	43	37	50	42	37	48	42	37	47	41	37	35	
8	61	48	39	34	60	47	39	33	46	38	33	45	38	33	43	37	33	31	
9	57	44	36	30	56	43	35	30	42	35	30	41	35	30	40	34	30	28	
10	54	41	33	27	52	40	32	27	39	32	27	38	32	27	37	31	27	25	