




# 23-7/8" 23-7/8"



### 2000/3000/4000

NOMINAL LUMENS	DELIVERED LUMENS	WATTAGE
4000	4536	37W
3000	3538	28W
2000	2591	19W

Based on 4000K, 85+ CRI. Actual wattage may vary +/- 5%

### **FEATURES**

1-3/4"

The clean design of the **Fully Luminous Decorative Troffer** transforms your lighting projects into a masterpiece of art.

This **unique 3D optical pattern** is a contemporary alternative to traditional fluorescent troffers. The **22-OAT3D-LED-DA design** delivers unmatched uniform light distribution.

Easily adjust brightness levels (multi-lumen) and color options (multi-CCT) in the field with multi-lumen and multi-CCT selectors. Perfect for offices, schools, healthcare, hospitals, retail, among other applications

### 4000/5000/6000

NOMINAL LUMENS	DELIVERED LUMENS	WATTAGE				
6000	5694	50W				
5000	4910	41W				
4000	3831	30W				

Based on 4000K, 85+ CRI. Actual wattage may vary +/- 5%

### 2000/3000/4000/5000

NOMINAL LUMENS	DELIVERED LUMENS	WATTAGE			
5000	4910	41W			
4000	4536	37W			
3000	3538	28W			
2000	2591	19W			

Based on 4000K, 85+ CRI. Actual wattage may vary +/- 5%

### **TECHNICAL DETAILS**

LUMENS	2000L/ 3000L/ 4000L   2000L/ 3000L/ 4000L/ 5000L 4000L/ 5000L/ 6000L   5000L/ 6000L/ 7000L
ССТ	35K/40K/50K
	30K/35K/40K
	30K/35K/40K/50K
CRI	85+
UGR	<19
COLOR QUALITY	3 Step MacAdam Ellipse

MOUNTING
Recessed, Suspended, Surface Mount

DIMMING
0-10V Flicker Free 10% Dimming Standard (Dim10)

EMERGENCY
10W-Up to 1000L output, 20W-Up to 2000L output

LIFETIME
L70 at 60,000 Hours

PHOTOMETRIC TST
In accordance with IES LM79-08, LM80 & TM30,TM21





















# 22-OAT3D-LED-DA 2'X2'

### **MAINTENANCE**

Luminaire can be regularly and safely wipe down to ensure the peak of performance.

### **OPTICAL SYSTEM**

Clear acrylic 0.125" matte PMMA, in 18 different 3D graphic image printed on inside lens surface, which protects it from cleaning solutions with scratch and impact resistant lens. Illumination is spread across the entire surface of the Architectural Panel, emitting soft, even light. A 110-degree beam angle ensures clear, shadow-free light.

### CONSTRUCTION

Narrow extruded aluminum is tightly held to code gauge steel back plate with seamless corners to maximize the light emitting surface with a refined finish. Acrylic Architectural Lens technology enables a wide-variety of 3D visual forms; all on an easy-to-clean flat surface.

### MOUNTING

Easy to install. Mounting hardware included. Accommodates lay-in ceilings, Slot T, and T bar suspension systems for 5/8" and 3/8" ceiling widths. Built-in grid and earthquake clips come standard. Options for flange kits, surface mounted kits and more. SMK required if suspending the fixture.

### **OPTIONS**

Luminaires can be shipped pre-installed with whips, modular wiring systems.

### **DRIVER ELECTRICAL INFORMATION**

Powered by high-quality constant-current power LED drivers wich are rated for 50 to 60Hz at 120/277V input provides noise free operation. Available in 347V; produce less than 20% THD, and have a power factor of .90 to 1.00.

### CONTROL OPTION

Compatible with field installed wireless controls such as daylight harvesting controls, occupancy sensors, and/or power packs for individual or room control applications

### **LED and PERFORMANCE**

The Mid power LED array provides an uniform source with high efficiency and no pixilation in +85 CRI minimum, R9 greater than 12 with 3 SDCM. The color Temperature (CCT) and Lumen has a selectable range from 3000K to 5000k color temperature and 2000 to 6000 lumen with 2 separate side mount slide switch located in the back of the luminaire.

### **DIMMING & DRIVER INFORMATION**

**DIM10** - Flicker Free and continuous 10% Dimming Standard (DIM10) 0-10V dimming on either MVOLT 120, 277V and 347V

### **WARRANTY**

Five-year warranty for parts and components. (Labor not included)

### LISTINGS


c-UL-us - Listed for Feed Through Wiring.

<u>Can be used to comply</u> with Tittle 24, non residential lighting requirements.

Damp location rated.

For DesignLights Consortium® (DLC) qualified products please visit www.designlights.org. Not all family members will be listed for DLC Premium or DLC Standard.

### Example: 22-OAT3D-LED-DA-2000L/3000L/4000L-DIM10-120-347V-30K/35K/40K-85






















### Fully Luminous Decorative Troffer With Multiple Lumens and CCT

### 22-OAT3D-LED-2000L-3000L-4000L-DIM10-MV0LT-35K-40K-50K-85(2000L)

INPUT WATTS: 19.4949 CCT: **3500K** SPACING CRITERIA: 1.42 LUMENS: **2597** CRI: N/A EFFICACY: **133** 

### **Candle Power Distribution (Candelas)**




ZUII	Zonai Lumens Summary													
Z	one	Lumens	%Lamp	%Fixt										
0-	-20	305.14	11.70	11.70										
0	-30	652.69	25.10	25.10										
0	-40	1079.38	41.60	41.60										
0	-60	1954.11	75.20	75.20										
0	-80	2497.12	96.20	96.20										
0	00	2571.01	00.00	00.00										

Luminance (Average candela/M²)												
Angle in Degrees	Average 0°	Average 45°	Average 90°									
45	2226	2269	2283									
55	2200	2262	2282									
65	2136	2227	2256									
75	2018	2162	2200									
85	1945	2331	2444									

	Lumens P	er Zo
•	Zone	Lu
	0-10	7
	10-20	22
	20-30	34
	30-40	42
	40-50	45
_	50-60	42
	60-70	33

70-80

80-90



TEST NO.: **EL05212049** 

**Coefficients of Utilization - Zonal Cavity Method** 

Effective Floor Cavity Reflectance 0.20

	RC		80	1%			70	)%			50%			30%			10%		0%	
	RW	70%	50%	30%	10%	70%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0%	
	0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99	
	1	108	103	98	94	105	100	96	92	96	92	89	92	89	86	88	86	84	81	
	2	98	89	82	76	95	87	80	75	83	78	73	80	75	71	77	73	69	67	
0	3	89	78	69	62	86	76	68	62	73	66	61	70	64	59	67	62	58	56	
Ē	4	81	69	60	53	79	67	59	52	65	57	51	62	56	50	60	54	50	47	
B/	5	74	61	52	45	72	60	51	45	58	50	44	56	49	44	54	48	43	41	
≟	6	69	55	46	39	67	54	45	39	52	44	38	50	43	38	48	42	38	35	
₹	7	64	50	41	34	62	49	40	34	47	39	34	46	39	34	44	38	33	31	
0	8	59	45	37	31	57	45	36	30	43	36	30	42	35	30	40	34	30	28	
O.	9	55	41	33	27	54	41	33	27	40	32	27	38	32	27	37	31	27	25	
80	10	52	38	30	25	50	38	30	25	37	29	25	36	29	24	35	29	24	22	
	0 0-111-	O D	- 61 4		D14/ 14/-11	D-414														•

RC - Ceiling Cavity Reflectance

RW - Wall Reflectance

### 22-OAT3D-LED-2000L-3000L-4000L-DIM10-MV0LT-35K-40K-50K-85(3000L)

INPUT WATTS: 28.8 LUMENS: **3638** CRI: N/A EFFICACY: **126** CCT: **3500K** 

### TEST NO.: **EL05212050** SPACING CRITERIA: 1.42

# **Candle Power Distribution (Candelas)** 580 870 20°

Zonal Lur	Zonal Lumens Summary												
Zone	Lumens	%Lamp	%Fixt										
0-20	424.85	11.70	11.70										
0-30	908.79	25.00	25.00										
0-40	1503.04	41.30	41.30										
0-60	2730.86	75.10	75.10										
0-80	3496.32	96.10	96.10										
0-90	3600.78	99.00	99.00										

Angle in Degrees	Average 0°	Average 45°	Average 90°		
45	3096	3153	3181		
55	3061	3143	3184		
65	2971	3094	3150		
75	2838	3033	3117		
85	2711	3244	3469		

Luminance (Average candela/M<sup>2</sup>

Lumens P	er Zone	Candela T	abulation_
Zone	Lumens		0
20.10		0.0	1155.504
0-10	109.45	5.0	1152.370
10-20	315.39	15.0	1116.480
20-30	483.94	25.0	1048.560
30-40	594.25	35.0	947.260
40-50	635.45	45.0	814.280
50-60	592.37	55.0	653.000
		65.0	467.050
60-70	470.92	75.0	273.200
70-80	294.54	85.0	87.900
80-90	104.46	90.0	14 460


Coefficients of Utilization - Zonal Cavity Method Effective Floor Cavity Reflectance 0.20

	RC		80	%			70	1%			50%			30%			10%		0%
	RW	70%	50%	30%	10%	70%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0%
	0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99
	1	108	103	98	94	105	100	96	92	96	92	89	92	89	86	88	86	84	81
	2	98	89	82	76	95	87	80	75	83	78	73	80	75	71	76	73	69	67
0	3	89	78	69	62	86	76	68	62	73	66	60	70	64	59	67	62	58	56
Ē	4	81	69	59	52	79	67	59	52	64	57	51	62	56	50	60	54	50	47
2	5	74	61	52	45	72	60	51	45	58	50	44	55	49	43	53	48	43	41
≧	6	68	55	46	39	66	54	45	39	52	44	38	50	43	38	48	42	37	35
₽	7	63	50	41	34	62	49	40	34	47	39	34	45	39	33	44	38	33	31
2	8	59	45	36	30	57	44	36	30	43	35	30	42	35	30	40	34	30	28
6	9	55	41	33	27	54	41	33	27	39	32	27	38	32	27	37	31	27	25
2	10	52	38	30	25	50	38	30	25	36	29	24	35	29	24	35	28	24	22
	RC - Ceilin	a Cavity F	eflectance		RW - Wall	Reflectan	ce												

### 22-0AT3D-LED-2000L-3000L-4000L-DIM10-MV0LT-35K-40K-50K-85(4000L)

TEST NO.: **EL05212051** INPUT WATTS: 37.4 SPACING CRITERIA: 1.42 **LUMENS: 4536** CRI: N/A EFFICACY: 121 CCT: 3500K

### **Candle Power Distribution (Candelas)**



Zonal Lur	nens Sumr	nary	
Zone	Lumens	%Lamp	%Fixt
0-20	530.24	11.70	11.70
0-30	1134.29	25.00	25.00
0-40	1876.05	41.40	41.40
0-60	3402.22	75.00	75.00
0-80	4358.49	96.10	96.10
0-90	4489.77	99.00	99.00

Angle in Degrees	Average 0°	Average 45°	Average 90°
45	3865	3938	3974
55	3820	3925	3981
65	3708	3862	3940
75	3544	3783	3918
85	3384	4051	4368

Luminan	ce (Average	e candela/	′M²)	Lumens P	er Zone	Candela T	abulation
Angle in Degrees	Average 0°	Average 45°	Average 90°	Zone	Lumens	0.0	<b>0</b> 1441.952
45	3865	3938	3974	0-10	136.60	5.0	1437.640
55 65	3820 3708	3925 3862	3981 3940	10-20 20-30 30-40	393.64 604.05 741.77	15.0 25.0 35.0	1393.830 1308.550 1182.000
75 85	3544 3384	3783 4051	3918 4368	40-50 50-60	788.05 738.12	45.0 55.0 65.0	1016.650 814.920 582.820
Method				60-70 70-80 80-90	588.50 367.77 131.28	75.0 85.0 90.0	341.150 109.710 18.020

### Coefficients of Utilization - Zonal Cavity Method

Effective Floor Cavity Reflectance 0.20

	RC		80	)%			70	)%			50%			30%			10%		0%
	RW	70%	50%	30%	10%	70%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0%
	0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99
	1	108	103	98	94	105	100	96	92	96	92	89	92	89	86	88	86	83	81
	2	98	89	82	76	95	87	80	75	83	78	73	80	75	71	76	73	69	67
0	3	89	78	69	62	86	76	68	62	73	66	60	70	64	59	67	62	58	56
RATI	4	81	68	59	52	79	67	59	52	64	57	51	62	56	50	60	54	50	47
2	5	74	61	52	45	72	60	51	45	58	50	44	55	49	43	53	48	43	41
≟	6	68	55	46	39	66	54	45	39	52	44	38	50	43	38	48	42	37	35
₽	7	63	50	41	34	62	49	40	34	47	39	34	45	39	33	44	38	33	31
2	8	59	45	36	30	57	44	36	30	43	35	30	42	35	30	40	34	30	28
8	9	55	41	33	27	54	41	33	27	40	32	27	38	32	27	37	31	27	25
8	10	52	38	30	25	50	38	30	25	36	29	24	35	29	24	35	28	24	22
$\neg$	RC - Ceilin	ng Cavity F	eflectance		RW - Wall	Reflectan	e												





## Fully Luminous Decorative Troffer With Multiple Lumens and CCT

22-0AT3D-LED-4000L-5000L-6000L-DIM10-120-347V-35K-40K-50K-85(4000L)

TEST NO.: **EL10052029** INPUT WATTS: 30.9 LUMENS: **3831** CRI: N/A EFFICACY: 124 CCT: **3500K** SPACING CRITERIA: 1.42

**Candle Power Distribution (Candelas)** 312 623 935 1246

Zonal Lur	nens Sumn	nary	
Zone	Lumens	%Lamp	%Fixt
0-20	453.15	11.80	11.80
0-30	967.59	25.30	25.30
0-40	1596.68	41.70	41.70
0-60	2886.68	75.40	75.40
0-80	3686.49	96.20	96.20
0-90	3793.1	99.00	99.00

Angle in Degrees	Average 0°	Average 45°	Average 90°
45	3271	3269	3269
55	3223	3217	3219
65	3134	3117	3113
75	3014	2990	2967
85	2906	2871	2850


Lumens P	er Zone	Candela T	abulation
Zone	Lumens		0
20110	Editiono	0.0	1234.645
0-10	116.90	5.0	1232.700
10-20	336.25	15.0	1192.190
20-30	514.44	25.0	1116.330
30-40	629.10	35.0	1005.990
40-50	668.76	45.0	860.200
		55.0	687.700
50-60	621.24	65.0	492.620
60-70	492.13	75.0	290.170
70-80	307.68	85.0	94.200
90.00	106.61	0.00	12 020

Coefficients of Utilization - Zonal Cavity Method Effective Floor Cavity Reflectance 0.20

	RC		80	)%			70	1%			50%			30%			10%		0%
	RW	70%	50%	30%	10%	70%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0%
	0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99
	1	108	103	98	94	105	100	96	92	96	92	89	92	89	86	88	86	84	81
	2	98	89	82	76	95	87	80	75	83	78	73	80	75	71	77	73	69	67
0	3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58	56
Ē	4	81	69	60	53	79	67	59	52	65	57	51	62	56	51	60	54	50	47
₩	5	74	61	52	45	72	60	51	45	58	50	44	56	49	44	54	48	43	41
≟	6	69	55	46	39	67	54	45	39	52	44	39	50	43	38	49	42	38	36
A	7	64	50	41	35	62	49	40	34	47	40	34	46	39	34	44	38	33	31
2	8	59	45	37	31	57	45	36	31	43	36	30	42	35	30	41	34	30	28
8	9	55	42	33	28	54	41	33	27	40	32	27	39	32	27	37	31	27	25
2	10	52	38	30	25	50	38	30	25	37	30	25	36	29	24	35	29	24	23
	C Coilin	a Covity D	ofloatonoc		DW Wall	Doflooton													

22-0AT3D-LED-4000L-5000L-6000L-DIM10-120-347V-35K-40K-50K-85(5000L)

INPUT WATTS: 41.5 LUMENS: **4910** CRI: N/A EFFICACY: 118 CCT: 3500K SPACING CRITERIA: 1.42



Zonal Lur	nens Sumn	nary		
Zone	Lumens	%Lamp	%Fixt	
0-20	582.38	11.90	11.90	
0-30	1243.39	25.30	25.30	
0-40	2051.59	41.80	41.80	
0-60	3700.14	75.40	75.40	
0-80	4725.16	96.20	96.20	
0-90	4861.42	99.00	99.00	

Luminance (Average candela/M²)												
Angle in Degrees	Average 0°	Average 45°	Average 90°									
45	4184	4194	4208									
55	4121	4122	4143									
65	3994	3992	4015									
75	3826	3817	3814									
85	3600	3657	3723									

Lumens P	er Zone	Candela T	abulation
Zone	Lumens	0.0	<b>0</b> 1586.679
0-10	150.20	5.0	1582.040
10-20	432.18	15.0	1531.540
20-30	661.02	25.0	1431.370
30-40	808.19	35.0	1288.010
40-50	854.13	45.0	1100.460
50-60	794.42	55.0	879.260
60-70	631.59	65.0 75.0	627.780 368.320
70-80	393.44	75.0 85.0	116.720
80-90	136.26	90.0	14.070


TEST NO.: **EL10052029** 

Coefficients of Utilization - Zonal Cavity Method Effective Floor Cavity Reflectance 0.20

	RC		80	%			70	1%			50%			30%			10%		0%
	RW	70%	50%	30%	10%	70%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0%
	0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99
	1	108	103	98	94	105	100	96	92	96	92	89	92	89	86	88	86	84	81
	2	98	89	82	76	95	87	80	75	83	78	73	80	75	71	77	73	69	67
0	3	89	78	69	63	86	76	68	62	73	66	61	70	64	60	67	62	58	56
Ē	4	81	69	60	53	79	67	59	52	65	57	51	62	56	51	60	54	50	48
8	5	74	61	52	45	72	60	51	45	58	50	44	56	49	44	54	48	43	41
≟	6	69	55	46	39	67	54	45	39	52	44	39	50	43	38	49	42	38	36
Ā	7	64	50	41	35	62	49	40	34	47	40	34	46	39	34	44	38	33	31
2	8	59	45	37	31	58	45	36	31	43	36	30	42	35	30	41	34	30	28
8	9	55	42	33	28	54	41	33	27	40	32	27	39	32	27	37	31	27	25
8	10	52	38	30	25	50	38	30	25	37	30	25	36	29	25	35	29	24	23
	RC - Ceilin	g Cavity B	eflectance		RW - Wall	Reflectano	:e												

22-0AT3D-LED-4000L-5000L-6000L-DIM10-120-347V-35K-40K-50K-85(6000L)

TEST NO.: **EL10052034** INPUT WATTS: 50.1 LUMENS: **5694** CRI: N/A EFFICACY: 114 CCT: 3500K SPACING CRITERIA: 1.42



2	Zonal Lumens Summary										
	Zone	Lumens	%Lamp	%Fixt							
	0-20	675.71	11.90	11.90							
	0-30	1442.7	25.30	25.30							
	0-40	2380.54	41.80	41.80							
	0-60	4289.98	75.30	75.30							
	0-80	5479.56	96.20	96.20							
	0-90	5637.82	99.00	99.00							

Angle in Degrees	Average 0°	Average 45°	Average 90°
45	4860	4872	4880
55	4777	4796	4816
65	4638	4637	4657
75	4426	4388	4405
85	4206	4201	4335

Luminance (Average candela/M<sup>2</sup>)

Lumens P	er Zone	Candela Tabulation						
Zone	Lumens		0					
20110	201110110	0.0	1841.245					
0-10	174.29	5.0	1836.170					
10-20	501.42	15.0	1776.490					
20-30	766.99	25.0	1662.800					
30-40	937.84	35.0	1496.350					
40-50	991.15	45.0	1278.260					
		55.0	1019.080					
50-60	918.29	65.0	729.050					
60-70	733.04	75.0	426.080					
70-80	456.54	85.0	136.350					
80-90	158.26	90.0	19.200					

Coefficients of Utilization - Zonal Cavity Method Effective Floor Cavity Reflectance 0.20

i	RC	80%			70%			50%			30%			10%			0%		
	RW	70%	50%	30%	10%	70%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0%
	0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99
	1	108	103	98	94	105	100	96	92	96	92	89	92	89	86	88	86	84	81
	2	98	89	82	76	95	87	80	75	83	78	73	80	75	71	77	73	69	67
0	3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58	56
Ē	4	81	69	60	53	79	67	59	52	65	57	51	62	56	51	60	54	50	48
Æ	5	74	61	52	45	72	60	51	45	58	50	44	56	49	44	54	48	43	41
≟	6	69	55	46	39	67	54	45	39	52	44	39	50	43	38	49	42	38	36
₹	7	64	50	41	35	62	49	40	34	47	40	34	46	39	34	44	38	33	31
2	8	59	45	37	31	58	45	36	31	43	36	30	42	35	30	41	34	30	28
8	9	55	42	33	28	54	41	33	27	40	32	27	39	32	27	37	31	27	25
8	10	52	38	30	25	50	38	30	25	37	30	25	36	29	25	35	29	24	23

RC - Ceiling Cavity Reflectance RW - Wall Reflectance