

SIZE	NOMINAL LUMENS	WATTAGE
16"	2000	24W
14"	1500	18W
12"	1200	14W

Based on 4000K, 85+ CRI. Actual wattage may vary +/- 5%

### **FEATURES**

The OMS is a low-profile, dimmable surface mount LED mushroom fixture; the perfect solution for upgrading incandescent surface mount luminaires in closets, hallways, corridors, bedrooms, offices, and more. Frosted acrylic diffuser provides ample, consistent illumination for spaces requiring low-maintenance, high-output lighting with an attractive appearance, including residential, hospitality, educational, and healthcare applications.

LUMENS	12" - 1200L 14" - 1500L 16" - 2000L
ССТ	27K/30K/35K/40K/50K
CRI	90+
COLOR QUALITY	3 Step MacAdam Ellipse
SIZE	12" and 16"
MOUNTING	Surface Mount
DIMMING & CONTROL	0-10V Flicker Free 5% Dimming Standard (DIM10), DIMTR
LIFETIME	L70 at 50,000 Hours
PHOTOMETRIC TESTS	In Accordance with IES LM79-08, LM80 and TM-30, TM-21

















Frosted, UV-stabilized white acrylic diffuser for low-glare, uniform illumination. Diffuser design and high lumen output provides a fully luminous appearance.

Heavy-gauge metal housing; frosted acrylic white diffuser.

### **INSTALLATION**

Luminaire easily mounts directly over a 4" recessed outlet box, and most standard junction boxes. Suitable for damp locations including laundry rooms, utility rooms, basements, and other environments exposed to moisture.

### DRIVER ELECTRICAL INFORMATION

Powered by high-quality constant-current power LED drivers which are rated for 50 to 60Hz at 120 or 120-277V input, produce less than 20% THD, and have a power factor of .90 to 1.00.

## **DIMMING & DRIVER INFORMATION**

DIM10 - Flicker Free 5% Dimming Standard (DIM10) 0-10V dimming on either MVOLT 120 or 277V(Consult Factory).


### **WARRANTY**

Five-year warranty for parts and components (labor not included).

### **LISTINGS**

ETL listed for damp locations **Energy Star** Title 24 JA8












### OMS-LED-16-2000L-DIMTR-120-27K-30K-35K-40K-50K-90

TEST NO.: EL07162043 SPACING CRITERIA: 1.42 INPUT WATTS: 24 LUMENS: **2495** CRI: **90** EFFICACY: 104 CCT: **2700K** 

# **Candle Power Distribution (Candelas)**



247

28.6

15.9

10.4

7.14

2

6

10

12

Zone	Lumens	%Lamp	%Fixt
0-20	262.47	10.5	10.5
0-30	561.3	22.5	22.5
0-40	928.64	37.2	37.2
0-60	1689.46	67.7	67.7
0-80	2198.15	88.1	88.1
0-90	2314.38	92.8	92.8

Angle in Degrees	Average 0°	Average 45°	Average 90°
45	6937	6921	6855
55	6982	6956	6868
65	7047	7002	6879
75	7393	7290	7193
85	11839	11505	11548

Lumens Pe	r Zone	Cande	la Tabulation
Zone	Lumens		<u>0</u>
0-10 10-20 20-30 30-40 40-50 50-60 60-70 70-80 80-90	67.65 194.81 298.83 367.34 391.89 368.93 301.83 206.87 116.22	0 5 15 25 35 45 55 65 75 85	714.407 714.2 694.67 654.23 594.73 515.91 421.17 313.23 201.24 108.52
		90	75.2

# Coefficients of Utilization - Zonal Cavity Method

Effective Floor Cavity Reflectance 0.20

	RC			80%		70%	,			50%	1		30%	,		10%	1		0%
	RW	70%	50%	30%	10%	70%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0%
ROOM CAVITY RATIO	0 1 2 3 4 5 6 7 8 9	117 106 95 87 79 73 67 62 58 54 50	117 100 86 75 66 59 53 48 44 40 37	117 95 79 67 57 50 44 39 35 32 29	117 91 73 60 50 43 37 33 29 26 24	114 102 92 83 76 70 64 60 56 52 49	114 97 84 73 65 58 52 47 43 39 36	114 93 77 65 56 49 43 38 34 31 28	114 89 71 59 50 42 37 32 29 26 23	107 91 79 69 61 55 49 45 41 37 35	107 88 73 62 54 47 42 37 33 30 28	107 85 69 57 48 41 36 32 28 25 23	101 86 75 65 58 52 47 43 39 36 33	101 83 70 60 52 45 40 36 32 29 27	101 81 66 55 47 40 35 31 28 25 22	95 82 71 62 55 49 45 41 37 34 32	95 79 67 57 50 44 39 35 31 29 26	95 77 63 53 45 39 34 30 27 24 22	93 74 61 51 43 37 32 28 25 22 20

BEAM DIA. MEASURED AT 50% OF NADIR F.C.

5.9

17.2

23.1

28.6

34.5

5.9

11.5 17.5

23.4

29.0

34.9

RC - Ceiling Cavity Reflectance

**Zonal Lumens Summary** 


RW - Wall Reflectance

# OMS-LED-12-1200L-DIMTR-120-27K-30K-35K-40K-50K-90

TEST NO.: EL07162043

INPUT WATTS: 13.8 LUMENS: **1330** EFFICACY: 96 CCT: 2700K SPACING CRITERIA: 1.42

# **Candle Power Distribution (Candelas)**



Zone	Lumens	%Lamp	%Fixt
0-20	122.38	9.2	9.2
0-30	262.55	19.7	19.7
0-40	436.35	32.8	32.8
0-60	804.37	60.5	60.5
0-80	1074.37	80.8	80.8
0-90	1153.44	86.8	86.7

Lumina	nce (Avera	age cande	ela/M²)	Lumens Pe	r Zone	Candela	a Tabulation
Angle in Degrees	Average 0°	Average 45°	Average 90°	Zone 0-10 10-20	Lumens 31.49 90.89	0 5	<u>0</u> 332.388 333.15
45 55 65 75 85	4924 5114 5459 6435 12691	4920 5116 5454 6436 12702	4791 4924 5178 6011 11644	20-30 30-40 40-50 50-60 60-70 70-80 80-90	140.17 173.79 187.72 180.3 153.75 116.24 79.07	15 25 35 45 55 65 75 85	326.25 310.54 286.57 254.3 214.24 168.49 121.63 80.78
						90	64.18

## Coefficients of Utilization - Zonal Cavity Method

Effective Floor Cavity Reflectance 0.20

	Cone of L	ight	
2	247	5.9	5.9
4	65.6	11.4	11.5
6	28.6	17.2	17.5
8	15.9	23.1	23.4
10	10.4	28.6	29.0
12	7.14	34.5	34.9
(FT.)Distance to Plane	(FC.) Initial Footcandle at	(FT.) Beam Vert, Scread	(FT.) Beam Horiz, Soread

EAM DIA. MEASURED AT 50% OF NADIR F.C.	<u></u>
	RC - Ce

	RC			80%		70%	)			50%	)		30%	•		10%	)		0%
	RW	70%	50%	30%	10%	70%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0%
ROOM CAVITY RATIO	0 1 2 3 4 5 6 7 8 9	116 104 93 85 77 71 65 60 56 52 49	116 98 84 73 64 57 51 46 42 39 35	116 93 77 64 55 48 42 37 33 30 27	116 88 70 57 48 41 35 31 27 25 22	112 99 89 81 74 68 62 58 54 50 47	112 94 81 71 62 55 50 45 41 37	112 90 74 62 54 47 41 36 33 30 27	1122 86 68 56 47 40 35 30 27 24 22	104 87 75 66 58 52 46 42 38 35 33	104 84 70 59 51 44 39 35 31 28 26	104 80 65 53 45 38 33 29 26 23 21	97 81 70 61 54 48 43 40 36 33 31	97 78 65 55 48 42 37 33 30 27 25	97 76 61 51 43 37 32 28 25 22 20	90 76 65 57 50 45 41 37 34 31 29	90 73 61 52 45 40 35 31 28 26 24	90 71 58 48 41 35 31 27 24 22 20	87 68 55 45 38 33 28 25 22 20 18

eiling Cavity Reflectance

RW - Wall Reflectance